



Certificate of Compliance

Certificate: 2779302

Master Contract: 203213

Project: 70053091

Date Issued: 2015-12-08

Issued to: Fronius International GmbH
Guenter Fronius Strasse 1
Wels-Thalheim, 4600
AUSTRIA

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Robert
Hempstock
Robert Hempstock

PRODUCTS

CLASS – 5311 09 - POWER SUPPLIES - Distributed Generation Power Systems Equipment

CLASS – 5311 89 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Transformerless Utility Interactive Inverter, Models Fronius Primo 3.8-1 208-240, Fronius Primo 5.0-1 208-240, Fronius Primo 6.0-1 208-240, Fronius Primo 7.6-1 208-240 and Fronius Primo 8.2-1 208-240, permanently connected.

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

APPLICABLE REQUIREMENTS

CSA-C22.2 No.107.1-01 - General Use Power Supplies

*UL Std No. 1741-Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment For Use With Distributed Energy Sources (Rev. January 7, 2015)

UL CRD - Non-Isolated EPS Interactive PV Inverters Rated Less Than 30kVA



Certificate: 2779302
Project: 70053091

Master Contract: 203213
Date Issued: 2015-12-08

UL 1699B	Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue Number 2, January 14, 2013)
CSA TIL M-07	Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue Number 1, March 11, 2013)

*Note: Conformity to UL 1741-Second Edition (Rev. January 7, 2015) includes compliance with applicable requirements of IEEE 1547 and IEEE 1547.1



Supplement to Certificate of Compliance

Certificate: 2779302

Master Contract: 203213

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70053091	2015-12-08	Update report 2779302 to include firmware revision, alternate components, and change to maximum continuous output current ratings.
70043703	2015-10-15	Update report 2779302 to include firmware revision and alternate components.
70036245	2015-07-07	Update report 2779302 to include firmware revision and alternate components.
70027816	2015-04-16	Update report 2779302 to include alternate components and firmware revision.
2779302	2014-12-10	PRIMO 1P7 Utility Interactive Inverter Series. (C/US)